



| SCALE CALIBRATION OPTIONS / DEFINITIONS | MAXIMUM PUMPING RATE/GAUGE VOLUME | SCALE CALIBRATION INCREMENT VALUE | DDC PART NUMBER |
|---|-----------------------------------|-----------------------------------|-----------------|
| DDC10,000-T =<br>ML BY VOLUME/GPH       | 158.503 GPH                       | 2 GPH                             | 17247           |
|   | 10,000 ML                         | 0.1 LITER                         |                 |
| DDC10,000-T-LPH =<br>ML BY VOLUME/LPH   | 600 LPH                           | 5 LPH                             | 56537           |
|   | 10,000 ML                         | 0.1 LITER                         |                 |

NOTE: GPH/LPH SCALES ARE BASED ON A ONE MINUTE TEST.

WETTED MATERIAL: PVC

DIMENSIONS ARE FOR REFERENCE PURPOSES ONLY AND ARE SUBJECT TO CHANGE AT ANY TIME WITHOUT NOTICE.

KENCO ORDER NUMBERS:  
DDC10,000-T  
DDC10,000-T-LPH

INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO.

TOLERANCES UNLESS OTHERWISE SPECIFIED

DECIMAL: ±.005" FRACTIONAL: ±1/64" ANGULAR: ±1/2°

**KENCO ENGINEERING COMPANY**  
TULSA, OKLAHOMA

CYLINDER, DRAW DOWN MODEL  
DDC10,000-T & DDC10,000-T-LPH

| REV. | DATE     | BY  | CHKD. | ECN    | EXPLANATION:  |
|------|----------|-----|-------|--------|---|
| B    | 05-03-02 | RDM | -     | N/A    | REDRAWN AND REVISED TO REFLECT NEW SILK SCREENED RATE/VOLUME SCALE PER ITEM 4 |
| C    | 08-06-08 | DS  | -     | N/A    | ADDED CHART; ADDED DDC10,000-T-LPH OPTION                                     |
| D    | 08-30-10 | DS  | PAS   | 000005 | ADDED SHEET 2   |

|                |               |                |
|----------------|---------------|----------------|
| DATE: 05-19-92 | SHEET: 1 OF 2 | DRAWING NUMBER |
| DRN. BY: TJW   | CHKD. BY:     | A-17247        |
| SCALE: NONE    | REVISION: D   |                |